

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:45 pm

PWS ID: UTAH23053 **Name:** ERDA ACRES WATER CO.
Legal Contact: ERDA ACRES WATER CO. **Rating:** Approved
ALAN G CLARK **Rating Date:** 06/08/1987
Address: PO BOX 11 **Activity Status:** Active
TOOELE, UT 84074
Phone Number: 435-882-0708
City Served (Area):
County: TOOELE COUNTY
System Type: Community **Last Inv Update:** 05/11/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 10/29/2009 **Total Dsgn Cap:**
Population: 1,000 **Surveyor:** VICKIE ROLFE **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	CLARK, ALAN G	PRESIDENT	801-244-4366	435-833-0165	aclark@trilobyte.net

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unknown	0	88
			88 Total Svc Connections

Storage

Total Storage: 1,000,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST002	1.0 MILLION GALLON TANK	Ground	1,000,000 GAL	Concrete		A	NO
ST001	STORAGE FACILITY ST001	Ground	100,000 GAL	Concrete		I	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	NELSON/CAMPBELL WELLS CHLORINATOR		P	

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	CAMPBELL BOOSTER PUMP	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #1 CAMPBELL (ABANI	Inactive	WL	6	60 GPM		Yes	GW	Permanent		
WS002	WELL #2 NELSON	Active	WL	10	700 GPM		Yes	GW	Permanent	1/1 to 12/31	
WS003	WELL #3 CAMPBELL	Active	WL	10	320 GPM		Yes	GW	Permanent	1/1 to 12/31	

**Reports measured flow for wells, approved design capacity for all other sources.*